

Business Name:

Business Address:

ABN/NZBN:

SOLAR PANEL CLEANING SAFE WORK METHOD STATEMENT (SWMS)












Business Contact:	Phone #:	Principal Contractor (PC):
Responsible person (for monitoring SWMS and work):		PC Address:
Signature:	Date:	PC Phone #: Date SWMS provided to PC:
Contact Phone #:		Job Site Address:

THIS WORK ACTIVITY INVOLVES THE FOLLOWING HAZARDOUS WORK AND ENVIRONMENTAL IMPACTS

- | | | | | |
|---|---|--|--|--|
| <input checked="" type="checkbox"/> Electrical equipment | <input type="checkbox"/> Elevated levels | <input checked="" type="checkbox"/> Slips, trips and falls | <input checked="" type="checkbox"/> Hazardous substances | <input type="checkbox"/> ? |
| <input type="checkbox"/> Hot Work | <input checked="" type="checkbox"/> Hazardous manual tasks | <input checked="" type="checkbox"/> Outdoor work | <input type="checkbox"/> Remotely &/or isolated work | <input type="checkbox"/> ? |
| <input checked="" type="checkbox"/> Noise and vibration | <input checked="" type="checkbox"/> Native vegetation & weeds | <input type="checkbox"/> Air quality | <input checked="" type="checkbox"/> Waste | <input checked="" type="checkbox"/> Vehicle movement |
| <input checked="" type="checkbox"/> Fuels, oils & chemicals | <input checked="" type="checkbox"/> Terrestrial fauna | <input checked="" type="checkbox"/> Waterways & soils | <input type="checkbox"/> Cultural heritage | <input type="checkbox"/> ? |

THIS WORK ACTIVITY INVOLVES THE FOLLOWING "HIGH-RISK CONSTRUCTION WORK" (HRCW - IDENTIFIED IN THE JOB TASK COLUMN)

- | | | | |
|---|--|---|--|
| <input type="checkbox"/> Confined spaces | <input type="checkbox"/> Mobile plant movement | <input type="checkbox"/> Demolition of a load-bearing structure | <input checked="" type="checkbox"/> Asbestos disturbance |
| <input type="checkbox"/> Using explosives | <input type="checkbox"/> Diving work | <input type="checkbox"/> Artificial extremes of temperature | <input type="checkbox"/> Tilt-up or pre-cast concrete |
| <input checked="" type="checkbox"/> Pressurised gas distribution mains or piping chemical, fuel or refrigerant lines energised electrical installations or services | | | |
| <input type="checkbox"/> Structures or buildings involving structural alterations or repairs that require temporary support to prevent collapse | | | |
| <input checked="" type="checkbox"/> Involves a risk of a person falling from 2m or more, including work on telecommunications towers | | | |
| <input type="checkbox"/> Working at depths greater than 1.5 Metres, including tunnels or mines | | <input type="checkbox"/> Work in an area that may have a contaminated or flammable atmosphere | |
| <input type="checkbox"/> Work carried out adjacent to a road, railway or shipping lane, traffic corridor | | <input type="checkbox"/> In or near water or other liquid that involves the risk of drowning | |

FOOT PROTECTION	HEARING PROTECTION	HIGH VISIBILITY	HEAD PROTECTION	EYE PROTECTION	FACE PROTECTION	HAND PROTECTION	PROTECTIVE CLOTHING	BREATHING PROTECTION	SUN PROTECTION	SAFETY HARNESS	Rings, watches, jewellery that may become entangled must not be worn. Long and loose hair must be tied back.
											
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION
ALMOST CERTAIN	3 - HIGH	3 - HIGH	4 - ACUTE	4 - ACUTE	4 - ACUTE		
LIKELY	2 - MODERATE	3 - HIGH	3 - HIGH	4 - ACUTE	4 - ACUTE	4A - ACUTE	DO NOT PROCEED.
POSSIBLE	1 - LOW	2 - MODERATE	3 - HIGH	4 - ACUTE	4 - ACUTE	3H - HIGH	Review before commencing work.
UNLIKELY	1 - LOW	1 - LOW	2 - MODERATE	3 - HIGH	4 - ACUTE	2M - MODERATE	Maintain control measures.
RARE	1 - LOW	1 - LOW	2 - MODERATE	3 - HIGH	3 - HIGH	1L - LOW	Record and monitor.



JOB TASK	HAZARDS	RISK	CONTROL MEASURES	RESPONSIBLE PERSON
1. Implement a Falls Emergency Rescue Plan	Personal injury from fall	4A	<ul style="list-style-type: none"> Trained first aid providers available Reliable means to contact emergency services available on site. 	Supervisor to ensure the plan is in place
2. HRCW Arrival on-site & assess onsite conditions	Personal injury, property damage &/or environmental incident	3H	<ul style="list-style-type: none"> The vehicle should be positioned in a safe location, clear of traffic/vehicles/pedestrians during equipment delivery and materials removal (deploy physical barriers, caution signs as necessary) Do not park illegally Identify and obey all safety-related signage (check site entry requirements) Report to Site Supervisor Ensure site-specific induction undertaken Assess mobile phone reception The worksite is exactly as detailed in Terms of Agreement or contract Complete a JSA specifying the control measures for unanticipated hazards. 	Supervisor to check the site and conduct JSA where necessary
	<ul style="list-style-type: none"> Fall from height Impact injuries Fatality 	4A	<ul style="list-style-type: none"> <i>Conduct risk assessment using 'WORKING AT HEIGHTS RISK ASSESSMENT CHECKLIST' supplied in this SWMS</i> ⚠ Based on the Risk Assessment for the task always ensure the highest possible level of controls is adopted. More than one of these measures to reduce risk can be used. 	
	Emergency	4A	<ul style="list-style-type: none"> Where the Risk Assessment has identified high-risk tasks, utilise a 'buddy' system where a second person is present at all times Do not expose both people to the hazard simultaneously. The second person should be within sight, but safely removed from the immediate area The 'buddy' must be trained in the specific activities the worker he/she is observing for is undertaking, be properly equipped with emergency equipment, and be capable of undertaking pre-planned rescue or emergency operations where needed. 	

JOB TASK	HAZARDS	RISK	CONTROL MEASURES	RESPONSIBLE PERSON	
			<ul style="list-style-type: none"> Do not use cleaning solutions containing hydrochloric acid, ammonia, or sodium hydroxide Do not brush or clean backside of panels. Avoid contact with lead wires or junction box ⚠ If any damage to the solar panels or supply cables occurs, stop work, and do not continue until a licensed electrical contractor has been able to attend and make the system safe. 		
11. HRCW On completion	Unauthorised access	3H	<ul style="list-style-type: none"> If acceptable, remove or add barricades Ensure machine is parked in a safe, level area, clear of unstable or sloping ground Store the key in a safe place (restrict unauthorised access). 	Supervisor to confirm all workers have signed out Workers to comply with controls	
	Contact with electricity	3H	<ul style="list-style-type: none"> Thoroughly inspect panels for cracks, damage, and loose connections. If damaged, consult with the owner to arrange to have the system inspected by a licensed electrical contractor and repaired Disconnect power tool/extension leads from power point before winding, so that you don't get a shock if the lead is damaged Inspect leads and power equipment for damage If safe to do so, remove isolation locks/tags and test appliance for function. 		
	Security breach	3H	<ul style="list-style-type: none"> All personnel sign-out on Site Register. 		
	Vehicle/people impact	4A	<ul style="list-style-type: none"> Stay to designated access and egress routes Maintain awareness of surroundings at all times. 		
12. HRCW Emergency response	<ul style="list-style-type: none"> Injury Fatality Environmental damage 	4A	<ul style="list-style-type: none"> For police, fire or ambulance call '000.' Follow site emergency and evacuation procedures A communication system is available, e.g. a mobile phone or radio Check for dangers to self before helping others Maintain control of the area and stabilise the situation Apply first aid to the injured worker Complete an incident report. 	<ul style="list-style-type: none"> Refer to your SWMS implementing instructions for further specific emergency responses. 	Supervisors and workers ensure controls followed

OVERALL RISK RATING AFTER CONTROLS

1 - Low

2 - MODERATE

3 - High

4 - ACUTE

PLANT & EQUIPMENT		HAZARDOUS SUBSTANCES	SUPERVISORY ARRANGEMENTS
<input type="checkbox"/> Electrical tools and leads	Tested and tagged quarterly	<i>List hazardous substances taken on-site and have the SDS onsite.</i> 1. 2. 3. 4. 5.	<input type="checkbox"/> Audits <input type="checkbox"/> Spot Checks <input type="checkbox"/> Reporting systems <input type="checkbox"/> Suitably qualified supervisors for job <input type="checkbox"/> Direct on-site supervision <input type="checkbox"/> Remote site: communication systems/schedule
<input type="checkbox"/> Hand tools - Meet AS/NZS	Regular visual inspection		
<input type="checkbox"/> Ladders - Meet AS/NZS	Inspected and tagged out if damaged		
<input type="checkbox"/> Mobile plant- <i>specify</i>	Inspected and tagged out if damaged		
<input type="checkbox"/> ?			